



Ref. Certif. No.

SE-112893

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit-breakers (MCCBs)

Name and address of the applicant

Wenzhou Tosun Electric Co., Ltd.
Room No.1001, Fortune Center, Station Road
Wenzhou, Zhejiang,
China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Wenzhou Tosun Electric Co., Ltd.
No.1 Huashan Road, Wenzhou Bridge Industrial Zone,
Baixiang, Yueqing, Zhejiang, China

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See page 2

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

TSB4-63

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007+A1+A2
IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

2309A1003SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 27 December, 2023

intertek

Signature:

Fredrik Wennersten

Ratings and principal characteristics

U_e = 220/230/240V~ (1P), 400/415V~ (2P, 3P, 4P)

I_n = 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A

I_{cu} = 10kA, I_{cs} = 7,5kA

I_{cs} = I_{cu} = 6kA

Cat.A, Ref. temperature: +30°C, +40°C, +50°C

U_{imp} = 4kV, U_i = 500V, Suitable for IT system

Date: 27 December, 2023

Signature:

A handwritten signature in black ink, appearing to be 'J. L. A.', written over a light blue background.