



Ref. Certif. No.

**SE-112603**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Moulded Case Circuit-Breakers

Name and address of the applicant

Wenzhou Tosun Electric Co., Ltd.  
Room No.1001, Fortune Center, Station Road, Wenzhou,  
Zhejiang, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Wenzhou Tosun Electric Co., Ltd.  
No.1 Huashan Road, Wenzhou Bridge Industrial Zone, Baixiang,  
Yueqing, Zhejiang, China

*Note: When more than one factory, please report on page 2*

☐ Additional Information on page 2

Ratings and principal characteristics

See page 2

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

TSB5-125

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

2308A1126SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden

Date: 22 November, 2023

intertek

Signature:

Fredrik Wennersten

**Rating and principal characteristics**

$U_e = 230/240V \sim$  for 1P, 400/415V~ for 2P, 3P, 4P, 50/60Hz,

$I_n = 10, 20, 25, 32, 40, 50, 63, 70, 80, 90, 100, 125A$ , Cat. A,

$I_{cu} = I_{cs} = 6kA$

$I_i = 10I_n, 12I_n$

ref. temperature  $+30^{\circ}C, +40^{\circ}C, +50^{\circ}C$

Date: 22 November, 2023

Signature:

A handwritten signature in black ink, appearing to be 'J. L. A.', is written over the signature line.