

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit-Breakers (MCCB)

Name and address of the applicant

Wenzhou Tosun Electric Co., Ltd.
Room No.1001, Fortune Center, Station Road, Wenzhou,
Zhejiang, China

Name and address of the manufacturer

Zhejiang Jiuce Intelligent Electric Co., Ltd.
No. 5, Fenjin Road, Dongfeng Industrial Zone, Liushi Town,
Yueqing City, Zhejiang Province, China

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as manufacturer

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

TSB5-63DC

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

220500856SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek

Signature:



Leif Mattsson

Date: 22 July, 2022

Ratings and principal characteristics

Ue= 250Vdc(1P), 500Vdc(2P), 750Vdc(3P), 1000Vdc(4P)

In= 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A

Ics= Icu= 6kA, Cat. A, Uimp= 4kV

Ui= 500V(1P, 2P), Ui= 1000V(3P, 4P)

Instantaneous(fixed): Ii= 5,5In, 8,5In, 10In

Date: 22 July, 2022

Signature: 