



Ref. Certif. No.

SE-110550IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Switch-disconnector

Name and address of the applicant

Wenzhou Tosun Electric Co., Ltd.
Room No.1001, Fortune Center, Station Road, Wenzhou,
Zhejiang, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Wenzhou Tosun Electric Co., Ltd.
No.1 Huashan Road, Wenzhou Bridge Industrial Zone,
Baixiang, Yueqing, Zhejiang, China.*Note: When more than one factory, please report on page 2*☐ Additional Information on page 2

Ratings and principal characteristics

Ue=230/240V~(1P), 400/415V~(2P, 3P, 4P), 50/60Hz
Ie=6, 10, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A,
Cat. AC-22A, Icw=3000A/1s, Icm=5000A,
Ui=500V. Uimp=4kV

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

TSQ7-125

Additional information (if necessary may also be
reported on page 2)☐ Additional Information on page 2A sample of the product was tested and found
to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which
forms part of this Certificate

230200377SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden
Date: 17 March, 2023

Signature:

Leif Mattsson